



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200236-H

Wisconsin Building Product Evaluation

Hot Water Boilers: Residential

Manufacturer: Slant/Fin Corporation
100 Forest Drive
Greenvale, NY 11548

Approved Product(s): Trade Name: **Victory VSP**

VSP-60, VSP-90, VSP-120, VSP-150 and VSP-180

For use in dwelling applications.

SCOPE OF EVALUATION: "This evaluation was based on receipt of a signed statement from the testing agency that the product passed the Wisconsin code required test(s) see test section. No other Department evaluation was conducted."

Applicant/Manufacturer: _____

Date: _____

ANSI Z21.47 (ANSI Z21.64): Access to the combustion chamber requires the use of tools.

_____ P.E.

Date: _____

TESTS: The Victory VSP Series low pressure hot water boilers, VSP-60, VSP-90, VSP-120, VSP-150 and VSP-180 were evaluated in accordance with ANSI Z21.13, the standard for Direct Vent Gas-Fired Low Pressure Steam and Hot Water Boilers tested and certified by CSA International.

LIMITATIONS OF APPROVAL: The boiler models covered by this evaluation meet the definition of a direct-vent sealed combustion chamber appliance specified in **s. Comm 51.01(29a)** and may be installed as allowed in **ss. Comm 64.21(2)(a) and (b)** and **s. Comm 23.04(3)** and **Table 23.04-A** and **s. IFGC 630.1 [Comm 65.0630]**.

The boilers shall be installed in accordance with their listing and the manufacturer's recommendations.

Boilers used for space heating shall be constructed and installed in accordance with the ASME Standards adopted under **s. Comm 41.40** of the Wisconsin Boiler and Pressure Vessel Code.

This approval will be valid through December 31, 2007, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: July 17, 2002 By: _____

Lee E. Finley, Jr.
Product/Material &
Building Plan Review
Integrated Services Bureau

200236-H.doc